

Content

---

Title : Effluent Standards [Ch](#)

Date : 2007.09.03

Legislative : Promulgation of amend provisions full 8 Articles by Order of Huan -Shu-Shui-Zi No. 0960065740, September 3 2007, It shall be implemented from the date of publication, Environmental Protection Administration, Executive Yuan

---

Content : Article 1

The Standards are established pursuant to Paragraph 2 of Article 7 of the Water Pollution Control Act (hereinafter referred to as the "Act").

Article 2

The water quality items and limits for the effluent standards of the enterprises, sewage systems and building sewage treatment facilities are specified below:

Article 4

The COD limits specified in the Standards shall be tested using the potassium dichromate reversal method; the true color shall be tested using the true color colorimetry.

Article 5

The limits of all the items, except for the hydrogen ion concentration index defined as a range, are defined as a maximum allowed value with the following measuring units:

I. Hydrogen ion concentration index: No unit

II. True color: No unit

III. Coliform group: CFU/100mL

IV. Other items: mg/L

Article 6

The limits of all the items, except for water temperature and hydrogen ion concentration index, of the non-contact cooling water that enterprises or sewage systems take from a water body and use it for cooling or circulation purpose are not subject to the Standards if it is discharged into the surface water body in the original water intake area.

Article 7

In the event that enterprises, sewage systems, or building sewage treatment facilities belong to two or more industry types within the scope of the Standards or to a single industry type but have different processes, the combined treatment and discharge of wastewater shall conform to the effluent standards for each of the concerned industry types. If different control limits are available for the same control item, the stricter limit shall apply. In the event that the flow of wastewater from one of the industry types in the preceding paragraph is at least 75% of the total flow of wastewater, and that independent and exclusive cumulative water measuring facilities have been installed, an application may be submitted to the competent authority for the use of the effluent standards of concerned industry type as the basis of control for all common items.

The percentage of the flow of wastewater in the preceding paragraph shall be calculated in accordance with the records of the six months prior to the date of application.

Article 8

The Standards come into force on the promulgation date.

---