

Table 2. The regulations for installing automatic monitoring (video) facility, electronic electricity meter and display panel for major violators or mandatory installers.

Item		Installation rules
Water capacity automatic monitoring device	Location of installation	<ol style="list-style-type: none"> 1. All water sources in the scope of operations 2. The outfall of discharging to the water body on ground surface 3. The outlet of discharging to the sewage system 4. The inlet and outlet for the storage facility with a permit obtained for storage installation
	Rules	Independent facility for measurement of water capacity in accumulation
Water quality automatic monitoring device	Location of installation	<ol style="list-style-type: none"> 1. All the components of water treatment facility at inlets and outlets for the installation of wastewater or sewage water treatment facilities 2. The outfall of discharging to the water body on ground surface 3. The outlet of discharging to the sewage system 4. The outlet for the storage facility with a permit obtained for storage installation
	Items for monitoring	<ol style="list-style-type: none"> 1. Water temperature 2. H⁺ concentration index 3. Conductivity 4. Other water quality item designated by the competent authority
CCTV device	Location of installation	<ol style="list-style-type: none"> 1. All the components of water treatment facility for the installation of wastewater or sewage water treatment facilities 2. The outfall of discharging to the water body on ground surface 3. The storage facility with a permit obtained for storage installation
	Rules	<ol style="list-style-type: none"> 1. With time recording function and sharp pictures on the screen 2. Round-the-clock monitoring
Online transmission facility		The data collected via the automatic monitoring devices and CCTV shall be transmitted to the competent authorities of the municipality or county (city) online via the Internet in the transmission module provided by the competent authorities of the municipality or county (city).
Electronic electricity meter		<ol style="list-style-type: none"> 1. Specifications shall be in accordance with relevant national standards 2. The measurement range of power consumption shall be at 1.2 times of the maximum power consumption of the wastewater or sewage water treatment/pretreatment facility,

Item		Installation rules
		<p>and it can continuously and automatically record the power consumption every fifteen minutes</p> <p>3. The electricity consumption data shall be available for the inspection of competent authorities and retained for five years.</p>
Display panel	Installation object	The outfall is installed in the operating environment and has been discovered by-pass discharge by the competent authority.
	Rules	<ol style="list-style-type: none"> 1. Should be placed in a conspicuous location at the main entrance 2. The size shall be based on the specifications approved by the competent authority 3. The display content shall include the control number, name of business operator, date, time, discharge water volume and water quality monitoring data, and public complaints hotline 4. The monitoring record of all monitoring items shall be displayed at the same time, and shall not be displayed in the form of a marquee. 5. The text shall be clearly visible without any pictures. 6. Firmly installed and cannot be moved easily